

DRINKING WATER NOTICE

City of Steubenville has levels of TTHM above Drinking Water Standards

Our water system recently violated the maximum contaminant level (MCL) for TTHM. The average level of TTHM was 0.085 mg/l. The standard for TTHM is 0.08 mg/l.

What should I do?

You do not need to use an alternative (e.g. bottled) water supply. However, if you have specific health concerns, consult your doctor.

What does this mean?

The levels detected do not pose an immediate risk to your health. Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous system, and may have an increased risk of getting cancer.

What is being done?

We are investigating the following necessary steps:

More thoroughly remove organic material prior to the disinfection process to correct the problem as soon as possible.

Additional information may be obtained by contacting:

Robert Disch
(740) 283-6041
1575 University Blvd.
Steubenville, Ohio, 43952.

Share this information with all other people who drink this water, especially those who may not have received this notice directly (People in apartments, nursing homes, schools or businesses.)

Date distributed August 26 , 2020
PWSID # OH4102411
Monitoring period: Third Quarter of 2020