

Utility Review Board Hearing: August, 2020

August 11, 2020: Sasha Sims, 2400 Sunset Blvd.

Sasha Sims did not show for the scheduled hearing nor call to cancel. Board denied the petition and no further hearing allowed for this matter.

Utility Review Board Hearing: September, 2020

September 8, 2020

Name: Ernestine Mixon 719 Alter St.

Dispute: On July 23, 2020, the City was working on a line replacement at the Old golf course. This line supplies water to the Alikanna area of the City. When the water was restored the Pressure Release Valve that controls the pressure to this area failed causing some of the customers to have complications with hot water tanks and other household items. Ms. Mixon experienced some problems that caused high consumption resulting in a higher than normal bill. She is asking for relief since this was out of her control.

Decision: The Review Board granted the petition since this was caused by a Faulty Pressure Valve.

Beverly/John Satkowski also had a hearing scheduled on this problem. They were told not to appear for the hearing. The Review Board granted this petition as well since the problem occurred due to the City's fault Pressure Valve.